

Benmiller Drinking Water System
2025
Operation and Maintenance
Annual Report

WW # 220007588
MDWL # 080-104 - #7 exp June 9, 2030
PTTW # 3180-BJKPVH, exp Dec. 13,2029
DWWP # 080-204 - #5, issued June 10, 2025

PREPARED BY

Veolia Water
100 Cove Rd.
Goderich, ON
N7A 3Z2

TO

Township of Ashfield-Colborne-Wawanosh,
82133 Council Line, R.R.#5,
Goderich, ON
N7A 3Y2

Table of Contents

- 1.0 INTRODUCTION AND BACKGROUND 4
- 2.0 DESCRIPTION OF WATER SYSTEM4/5
- 3.0 SUMMARY OF WATER QUALITY MONITORING 6
 - 3.1 Water Treatment Equipment Operation and Monitoring as Per Schedule 7, O. Reg 170/03..... 6
 - 3.1.1 Point of Entry Chlorine Residual 6
 - 3.1.2 Distribution Chlorine Residual 6
 - 3.1.3 Turbidity 7
 - 3.2 Microbiological Sampling as per Schedule 10, O. Reg.170/03 8
 - 3.2.1 Raw System8
 - 3.2.2 Treated Water Samples 9
 - 3.2.3 Distribution Samples 10
 - 3.3 Chemical Sampling & Testing as per Schedule 13, O. Reg.170/03 11
 - 3.3.1 Inorganics 11
 - 3.3.2 Lead11
 - 3.3.3 Organics12-13
 - 3.3.4 Trihalomethanes and Haloacetic Acids..... 14
 - 3.3.5 Nitrate & Nitrite 14
 - 3.3.6 Sodium 15
 - 3.3.7 Fluoride 15
- 4.0 WATER AND CHEMICAL USAGE15
 - 4.1 Chemical Usage15
 - 4.2 Annual Flows16
- 5.0 IMPROVEMENTS TO SYSTEM AND ROUTINE AND PREVENTATIVE MAINTENANCE.....17
- 6.0 MINISTRY OF THE ENVIRONMENT INSPECTIONS AND REGULATORY ISSUES18
- 7.0 MECP Regulatory Changes.....18

List of Tables

Table 1 – *Treated and Distribution Chlorine Residuals for Benmiller Drinking Water System*

Table 2 – *Raw and Treated Water Turbidities for Benmiller Drinking Water System*

Table 3 – *Microbiological Results for Raw Water at Benmiller Drinking Water System*

Table 4 – *Microbiological Results for Point of Entry at Benmiller Drinking Water System*

Table 5 – *Microbiological Results for Benmiller Distribution System*

Table 6 – *Schedule 23 Results for Benmiller Drinking Water System*

Table 7 – *Lead Sampling Program Results for Benmiller Drinking Water System*

Table 8 – *Schedule 24 Results for Benmiller Drinking Water System*

Table 9 – *Nitrate, Nitrite, THM and HAA Results at Benmiller Drinking Water System*

Table 10 – *Chemical Usage at the Benmiller Drinking Water System*

Table 11 – *Treated Water Flows for Benmiller Drinking Water System*

Table 12. –*Regulatory Requirements*

1.0 INTRODUCTION AND BACKGROUND

The purpose of the 2025 Annual Report is to document the operation and maintenance data for the Benmiller Drinking Water System for review by the Ministry of Environment, Conservation and Parks in accordance with O. Reg. 170/03. This report covers January 1, 2025 to December 31, 2025. A copy of this report will be submitted to the owner to be uploaded to the township's website and can be supplied to interested parties upon request.

2.0 DESCRIPTION OF WATER SYSTEM

The Benmiller Drinking Water System (DWS # **220007588**), is characterized as a "secure ground water" system and is classified as a small municipal residential system. The system consists of one well with a rated capacity of 196 m³/day, with chlorination treatment. The entire system is located on Concession 1, Part Lot 1, Eastern Division of Ashfield-Colborne-Wawanosh Township. The distribution system serves the community of Benmiller with a population of approximately 60 residents, with approximately 22 customer services, and a 47 guest room Inn and a Community Hall.

The system consists of a Limited Drinking Water System, which is owned by the Township of Ashfield-Colborne-Wawanosh and operated by Veolia Water Canada, the Operating Authority.

Well # 2 was put into service in January 2016, replacing # 1 well. It is a 150 mm drilled well, 70.1 m deep, originally drilled as a monitoring well in 2006. Well # 2 is equipped with a submersible vertical turbine pump rated at 2.5 L/s at 56.4 m TDH.

The well house is equipped with a well pump, flow restrictor limiting flow to 2.27 litres/second, back-up diesel generator, chlorinators, a chlorine contact reservoir, on-line monitoring and alarm generation and auto-dialer.

Back-up power is supplied by one 20 KW, 25 kVA diesel standby generator with automatic transfer switch and 340 L double wall sub-base fuel tank, all installed in an external weatherproof and acoustic enclosure on a concrete pad.

The well house and its equipment have a daily maximum capacity to deliver 196 cubic metres of potable water per day to the Benmiller community. The current water source is one secure deep bedrock well. The well is located on the well house site with a dedicated raw water main feeding the well house.

The water from the well is pumped to a chlorine contact / storage reservoir (7.6 m x 4.6 m x 3.8 m deep) to provide adequate chlorine contact time at maximum flow and before the first consumer, complete with a sampling / service water connection feed back to the pump house.

The well house is monitored by an alarm dialer and is equipped with a data logger that tracks chlorine residuals on the treated water.

The attached distribution system is constructed with a combination of galvanized steel and PVC piping with polyethylene services.

There is no elevated storage to maintain pressure and the system pressure is maintained using pressure tanks and 3 pressure pumps.

The system has no fire hydrants and lacks the capacity to provide fire flows.

Disinfection is achieved on the Benmiller well supply through the use of 6% sodium hypochlorite. In the well house this chemical is added prior to the water entering the chlorine contact reservoir at dosages high enough to achieve both primary and secondary disinfection objectives.

The chlorine dosages range varies with the chlorine demand of the raw water.

The free chlorine residual is monitored at the point of entry to the distribution system, by an on-line chlorine analyzer, with a target residual of > 1.00 mg/l and < 1.30 mg/l.

The Benmiller well supply has 1 PTTW (Permit To Take Water) #3180-BJKPVH issued December 27, 2019, with an expiry date of December 13, 2029, which allows 196 cubic metres per day to be pumped from the well.

The Benmiller Drinking Water System (treatment Subsystem) has maximum flows as specified in the Municipal Drinking Water Licence (MDWL) 080-104 and Drinking Water Works Permit (DWWP) 080-204 Issue #4 . The maximum total daily flow is 196 cubic meters per day.

The treated water is monitored by an on-line chlorine analyzer.

Distribution piping typically ranges in size from 50 mm to 100 mm, and consists of galvanized or PVC piping, with polyethylene service connections.

A 100 mm diameter discharge water main outside the pump house supplies treated water to the Benmiller Estates Subdivision, and two 50 mm discharge water main supplies treated water to the Benmiller Inn.

Typical system pressure ranges from 40 P.S.I to 60 P.S.I.

3.0 SUMMARY OF WATER QUALITY MONITORING

3.1 Water Treatment Equipment Operation and Monitoring

3.1.1 Point of Entry Chlorine Residual

Chlorine residuals are continuously measured using a HACH sc10 online chlorine analyzer and verified for accuracy using a hand-held HACH pocket colorimeter (364 samples were collected).

Table 1 shows the monthly average of free chlorine residual values on the treated water at the point of entry.

3.1.2 Distribution Chlorine Residual

Chlorine residuals in the distribution system are checked daily using a HACH pocket colorimeter. 363 distribution chlorine residuals were recorded.

Table 1. – Treated and Distribution Chlorine Residuals for Benmiller Drinking Water System

Date	Average Treated Chlorine Residual (mg/L)	Average Distribution Chlorine Residual (mg/L)
Jan	1.62	1.56
Feb	1.65	1.63
Mar	1.62	1.56
Apr	1.74	1.63
May	1.66	1.50
Jun	1.68	1.52
Jul*	1.55	1.47
Aug	1.65	1.55
Sept	1.78	1.63
Oct	1.65	1.53
Nov	1.71	1.57
Dec	1.66	1.50
Average	1.66	1.55
Min	0.81	0.80
Max	2.06	2.12
# Samples	364	363

* Samples missed Feb due to road closures

3.1.3 Turbidity

The Treated Turbidity and Raw Turbidity is recorded at least once a month using a HACH pocket turbidimeter. The maximum turbidity measured in the treated water was 0.60 NTU and 1.03 NTU in the raw water.

Table 2 provides a summary of raw and treated turbidity results.

Table 2. – Raw and Treated Water Turbidities for Benmiller Drinking Water System

Date	Average Raw Turbidity (NTU)	Average Treated Turbidity (NTU)
Jan	0.84	0.60
Feb	0.58	0.39
Mar	0.84	0.60
Apr	0.50	0.41
May	1.03	0.40
Jun	0.64	0.53
Jul	0.57	0.48
Aug	0.81	0.37
Sep	0.34	0.26
Oct	0.39	0.32
Nov	0.20	0.27
Dec	0.56	0.37
Average	0.61	0.42
Min	0.20	0.26
Max	1.03	0.60
# Samples	25	103

3.2 Microbiological Sampling

3.2.1 Raw Water Samples

Raw water samples are taken every two weeks. A total of 28 samples were collected and analyzed for E. Coli and Total Coliforms. Each E. Coli and Total Coliform sample results were 0 cfu/100 ml in the raw water.

Table 3 provides a summary of bacteriological results performed on the raw water.

Table 3. – Microbiological Results for Raw Water at Benmiller Drinking Water System

Date	E. Coli			Total Coliform		
	# Samples	# Samples 0	# Samples ≥1	# Samples	# Samples 0	# Samples ≥1
Jan	2	2	0	2	2	0
Feb	2	2	0	2	2	0
Mar	2	2	0	2	2	0
Apr	3	3	0	3	3	0
May	2	2	0	2	2	0
Jun	2	2	0	2	2	0
Jul	2	2	0	2	2	0
Aug	2	2	0	2	2	0
Sep	3	3	0	3	3	0
Oct	3	3	0	3	3	0
Nov	2	2	0	2	2	0
Dec	3	3	0	3	3	0
Total	28	28	0	28	28	0

3.2.2 Treated Water (Point of Entry) Samples

One treated water sample from the point of entry is taken every two weeks and analyzed for E.Coli, Total Coliforms and for Heterotrophic Plate Count (HPC). A total of 30 E.Coli and Total Coliforms water samples were collected and analyzed for the above parameters. Each E. Coli and Total Coliform test result from the treated water was 0 cfu/100 ml. The range of HPC results were 0 - 70 cfu/100 ml (may be high due to unreliable blank at testing) .

Table 4 provides a summary of all bacteriological results performed on treated water.

Table 4. – Microbiological Results for Point of Entry at Benmiller Drinking Water System

Date	E. Coli			Total Coliform			HPC		
	# Samples	# Samples 0	# Samples ≥1	# Samples	# Samples 0	# Samples ≥1	# Samples	Safe	Deteriorating
Jan	2	2	0	2	2	0	2	2	0
Feb	2	2	0	2	2	0	2	2	0
Mar	2	2	0	2	2	0	2	2	0
Apr	3	3	0	3	3	0	3	3	0
May	2	2	0	2	2	0	2	2	0
Jun	2	2	0	2	2	0	2	2	0
Jul	2	2	0	2	2	0	2	2	0
Aug	*4	*4	0	*4	*4	0	*4	*4	0
Sep	3	3	0	3	3	0	3	3	0
Oct	3	3	0	3	3	0	3	3	0
Nov	2	2	0	2	2	0	2	2	0
Dec	3	3	0	3	3	0	3	3	0
Total	30	30	0	30	30	0	30	30	0

August had extra samples taken due to AWQI #169293

3.2.3 Distribution System

Distribution samples are collected every two weeks and tested for E.Coli, Total Coliform and for Heterotrophic Plate Count (HPC). A total of 30 distribution samples were collected and analyzed for the above parameters. All E. Coli and Total Coliform results from the treated water were 0 cfu/100 ml. The range of HPC results were 0 - <10 cfu/100 ml (may be high due to unreliable blank at testing).

Table 5 provides a summary of all bacteriological samples taken in the distribution system.

Table 5. – Microbiological Results for Benmiller Distribution System

Date	E.Coli			Total Coliform			HPC		
	# Samples	# Samples 0	# Samples ≥1	# Samples	# Samples 0	# Samples ≥1	# Samples	Safe	Deteriorating
Jan	2	2	0	2	2	0	2	2	0
Feb	2	2	0	2	2	0	2	2	0
Mar	2	2	0	2	2	0	2	2	0
Apr	3	3	0	3	3	0	3	3	0
May	2	2	0	2	2	0	2	2	0
Jun	2	2	0	2	2	0	2	2	0
Jul	2	2	0	2	2	0	2	2	0
Aug	*4	*4	0	*4	*4	0	*4	*4	0
Sep	3	3	0	3	3	0	3	3	0
Oct	3	3	0	3	3	0	3	3	0
Nov	2	2	0	2	2	0	2	2	0
Dec	3	3	0	3	3	0	3	3	0
Total	30	30	0	30	30	0	30	30	0

August had extra samples taken due to AWQI #169293

3.3 Chemical Sampling & Testing

3.3.1 Inorganics

One treated water sample is taken every 60 months and tested for inorganics. The most recent samples for the Benmiller Drinking Water System were collected on July 8, 2021 and submitted to the laboratory for analysis of inorganics as listed in Schedule 23. All parameters were found to be within compliance. Inorganics will be sampled and analyzed again on or before **July 8, 2026**.

Results from 2021 can be found in **Table 6**.

Table 6. – Schedule 23 Results for Benmiller Drinking Water System

Parameter	Result (µg/L)	Maximum Allowable Concentration (µg/L)
Antimony	<0.9	6
Arsenic	2.6	10
Barium	77.9	1000
Boron	92	5000
Cadmium	0.004	5
Chromium	0.25	50
Mercury	<0.01	1
Selenium	<0.04	10
Uranium	0.585	20

3.3.2 Lead

Schedule 15.1 of Ontario Regulation 170/03 requires that samples be taken during two seasons: once between December 15 and April 15 and once between June 15 and October 15. The Maximum Allowable Concentration for Lead is 10 µg/L.

Results can be found in **Table 7**.

Table 7. – Lead Sampling Program Results for Benmiller Drinking Water System

	Lead (µg/L)	pH	Alkalinity (mg/L)
Dec-Apr	<0.01	7.72	212
Jun-Oct	0.48	8.02	214

3.3.3 Organics

One treated water sample is taken every 60 months and tested for schedule 24 organic parameters. The most recent samples were collected on June 21, 2021. All parameters were found to be within compliance. Organics will be sampled and analyzed again on or before **June 21, 2026**.

2021 sample results can be found in **Table 8**.

Table 8. – Schedule 24 Results for Benmiller Drinking Water System

Parameter	Result (µg/L)	Maximum Allowable Concentration (µg/L)
Benzene	<0.32	1
Carbon Tetrachloride	<0.17	2
1,2-Dichlorobenzene	<0.41	200
1,4-Dichlorobenzene	<0.36	5
1,1-Dichloroethylene	<0.33	14
1,2-Dichloroethane	<0.35	5
Dichloromethane	<0.35	50
Monochlorobenzene	<0.3	80
Tetrachloroethylene	<0.35	30
Trichloroethylene	<0.44	50
Vinyl Chloride	<0.17	1
Diquat	<1	70
Paraquat	<1	10
Glyphosate	<1	280
Polychlorinated Biphenyls	<0.04	3
Benzo(a)pyrene	<0.004	0.01
2,4-dichlorophenol	<0.15	900
2,4,6-trichlorophenol	<0.25	5
2,3,4,6-tetrachlorophenol	<0.20	100
Pentachlorophenol	<0.15	60
Alachlor	<0.02	5
Atrazine+N-dealkylated metabolites	<0.01	5
Atrazine	<0.01	-
De-ethylated atrazine	<0.01	-
Azinphos-methyl	<0.05	20
Carbaryl	<0.05	90
Carbofuran	<0.01	90
Chlorpyrifos	<0.02	90
Diazinon	<0.02	20
Dimethoate	<0.06	20

Table #8 con't

Parameter	Result (µg/L)	Maximum Allowable Concentration (µg/L)
Diuron	<0.03	150
Malathion	<0.02	190
Metribuzin	<0.02	80
Phorate	<0.01	2
Prometryne	<0.03	1
Simazine	<0.01	10
Terbufos	<0.01	1
Triallate	<0.01	230
Trifluralin	<0.02	45
2,4-dichlorophenoxyacetic acid	<0.19	100
Bromoxynil	<0.33	5
Dicamba	<0.20	120
Diclofop-methyl	<0.40	9
MCPA	<0.00012	0.00012
Picloram	<1	190

3.3.4 Trihalomethanes and Haloacetic Acids

One distribution sample is taken every three months and tested for Trihalomethanes (THMs) and Haloacetic Acids (HAAs). In 2025, samples were collected during the months of March, June, September and December. The Ontario Drinking Water Quality Standard (ODWQS) has set a Maximum Allowable Concentration (MAC) of 100 µg/L for THMs and it is expressed as a running annual average. The RAA for THMs was found to be 11 µg/L. The HAA MAC is 80 µg/L. All samples were found to be within compliance.

Refer to **Table 9** for the summary of trihalomethane and haloacetic acid results.

3.3.5 Nitrate & Nitrite

One treated water sample is taken every three months and tested for nitrate and nitrite. Samples were collected during the months of March, June, Sept and December. The Ontario Drinking Water Quality Standard (ODWQS) has set a Maximum Allowable Concentration (MAC) of 1 mg/L for nitrites and 10 mg/L for nitrates. All results were found to be within compliance.

Refer to **Table 9**:

Table 9. – Nitrate, Nitrite, THM and HAA Results at Benmiller Drinking Water System

Date	Nitrate		Nitrite		THMs		HAAs	
	# Samples	Result (mg/L)	# Samples	Result (mg/L)	# Samples	Result (µg/L)	# Samples	Result (µg/L)
March 5	1	<0.006	1	<0.003	1	7.1	1	<5.3
June 10	1	<0.006	1	<0.003	1	19	1	<5.3
Sept. 15	1	<0.006	1	<0.003	1	10	1	<5.3
Dec.	1	<0.006	1	<0.003	1	6.2	1	<5.3
Total	4		4		4		4	
Average		<0.006		<0.003		RAA 11		<5.3
Maximum		<0.006		<0.003				<5.3

3.3.6 Sodium

One treated water sample is collected every 60 months and tested for Sodium. O. Reg 170/03 has set a Maximum Acceptable concentration (MAC) of 20 mg/L for Sodium which requires the Medical Office of Health be notified if the concentration exceeds the MAC. These samples were last collected on June 15, 2021 and were found to be 18.5 mg/L, which is within compliance.

The next water sample for Sodium will be collected and analyzed on or before **June 15, 2026**.

3.3.7 Fluoride

One treated water sample is collected at least once every 60 months and tested for Fluoride. The Ontario Drinking Water Quality Standards (ODWQS) have set a **MAC** of **1.5** mg/L. On August 23rd and a resample on Aug. 30th, 2022 samples were collected for this analysis. The samples were both found to be above the **MAC**, 1.92 mg/L and 1.83 mg/L respectively. This is due to high levels of naturally occurring fluoride in the aquifer.

The next water sample for Fluoride will be collected and analyzed in August , 2027.

For more information see:

<http://www.acwtownship.ca/wordpress/wp-content/uploads/2013/09/Benmiller.pdf>.

4.0 WATER AND CHEMICAL USAGE

4.1 Chemical Usage

A total of 54.06 kg of sodium hypochlorite was used to ensure proper disinfection in the distribution system with an average dosage of 3.65 mg/L.

Refer to **Table 10**.

Table 10. – Chemical Usage at Benmiller Drinking Water System

Date	Sodium Hypochlorite	
	Total Usage (kg)	Average Dosage (mg/L)
Jan	3.19	3.72
Feb	3.71	3.88
Mar	3.19	3.72
Apr	3.58	3.82
May	4.23	3.52
Jun	6.96	4.13
Jul	5.46	3.10
Aug	7.15	3.70
Sep	4.81	3.44
Oct	3.84	3.29
Nov	3.71	3.93
Dec	4.23	3.58
Total	54.06	–
Average	–	3.65

4.2 Annual Flows

A summary of the water supplied to the distribution system is provided in **Table 11**. This Table provides a breakdown of the monthly flow provided to the distribution system.

Flow meters were calibrated in July 2025 by Advanced Meter Service and were found to be acceptable.

Table 11. – Treated Water Flows for Benmiller Drinking Water System

Date	Total Monthly Flow (m³)	Maximum Daily Flow (m³)	Average Daily Flow (M³)
Jan	847	48	27
Feb	947	75	35
Mar	939	58	30
Apr	942	54	31
May	1,224	62	39
Jun	1,887	150	63
Jul	1,753	85	57
Aug	2,041	181	66
Sep	1,406	83	47
Oct	1,157	78	37
Nov	1,020	92	34
Dec	1,207	56	39
Total	15,370	–	–
Max	–	181	–
Average	–	–	42

5.0 IMPROVEMENTS TO SYSTEM AND ROUTINE AND PREVENTATIVE MAINTENANCE

The following summarizes water system improvements and routine and preventative maintenance for the Benmiller Drinking Water System:

- RM Electric repaired the HLP duty selection (pressure switch needs replacing)
- Yearly analyzer calibration was completed by Cleartech
- The flow meter was calibrated
- Annual generator check was completed by Sommers Generator Service
- Lead pressure switch was repaired
- Pressure tank was replaced
- Operational Manual, /Plan and Contingency Plans updated
- BC fire extinguisher replaced the ABC fire extinguisher
- Monthly maintenance was completed

6.0 MINISTRY OF THE ENVIRONMENT INSPECTIONS AND REGULATORY ISSUES

The most recent inspection conducted by The Ministry of Environment, Conservation and Parks was completed by Ron Burrel in May 2025 and a rating of 100% was given.

There were no non-compliances noted.

- It should be noted that an entry was not filled out in June due to flooding in the well house (logbook was soaked) but an entry was made on the logsheet for that day.

A Reaccreditation Audit was conducted by SAI Global and issued in May 2025.

There was 1 Opportunity for Improvement (OFI):

- Operational Plan section 13 Essential Supplies and Services Table - Consider adding suppliers for Sodium Silicate and UV System Parts/Supplies.(Sodium silicate and UV are not used at this site)

There were 0 instances of adverse water quality:

There was 1 Precautionary Boil Water Notice (BWA):

- AWQI #169293 - Watermain break

There was 1 instance of nonconformance.

- Site was not able to be completed due to road closures

There were 2 Watermain breaks.

7.0 MECP Regulatory Changes

- Proposed amendments to drinking water operator and water quality analyst certification regulations have been issued to address the impacts of emergencies. These include:
 - allowing the Ministry to act quickly to ensure the Province’s drinking water is protected during an emergency
 - extending Operator certificates and allowing certain qualified but non-certified staff to temporarily maintain system operations, and would only be enacted during an emergency
 - allowing temporary relief from training and certification requirements

This proposal has been registered with the Environmental Registry of Ontario and the consultation process was closed on July 2, 2021. The outcome of this proposal is expected to be published in 2022.

- Proposed updates to the Director’s Directions - Minimum Requirements for Operational Plans - May 2021. The Director’s Directions have updated the following:
 - Content Requirements - all referenced documents will be considered part of the Operational Plan.
 - Procedures for version control - version number and revision date is to be embedded in every electronic copy, and recorded on every page of any physical copy
 - Completed copy of Subject System Description Form in Schedule “C” of the Director’s Directions
 - Operational Plans are to be submitted to the Director electronically
 - Retention of Operational Plans - Operational Plans that were the subject of an audit by an auditor for the accreditation body shall be retained for a minimum of 10 years
 - Public Disclosure of Operational Plans - shall be made available for viewing by the public either electronically (website) or at the principal place of business, but not in a manner that would threaten the safety, health or quality of the drinking water, or create significant prejudice with the contractual obligations of the Operating Authority or other organization.
 - Operational Plans shall be updated to meet the requirements of the Director’s Directions no later than April 1, 2022.



Report Date: February 13, 2026

Benmiller Drinking Water System – 2025 Compliance Summary

This document is a compliance summary for the Benmiller water supply for the year 2025 as per O. Reg. 170/03 Schedule 22. A full summary of the water system's test results, flows and significant activities was submitted in the Annual Report.

System Description

The Benmiller water system is characterized as a “secure ground water” system and is classified as a small municipally owned water system.

The well house and its equipment have a daily maximum capacity to deliver 196.4 cubic meters of potable water per day to the Benmiller community. This was not exceeded during 2025.

A monitoring well, drilled due west of the well house in 2007, was constructed by the Maitland Valley Conservation Association to monitor water movement in the aquifer. It was constructed to municipal production standards. This secure deep bedrock well (Well #2) was put into service in January 2015 including a new well pump and water main, and well #1 was officially abandoned at that time.

The water system is monitored bi-weekly for bacteriological analysis to ensure the integrity of the water coming from the well.

The well house is equipped with a data logger, backup diesel generator, chlorinators, a chlorine contact reservoir, online monitoring and alarm generation from an Autodialer.

The distribution system is constructed of a combination of galvanized steel and PVC piping with polyethylene services.

There is no elevated storage to maintain pressure and the system pressure is maintained using pressure tanks and the three horizontal pumps. There is a backup generator with automatic switchover.

The system has no hydrants and lacks the capacity to provide fire flows.

Chemicals Fed

Disinfectant

Disinfection was achieved in the Benmiller well supply through the use of 6% sodium hypochlorite. In the well house this chemical was added prior to the water entering the chlorine contact reservoir at dosages high enough to achieve both primary and secondary disinfection objectives. The chlorine average dosages ranged from 3.10 mg/L to 4.17 mg/L, varying with the chlorine demand of the raw water.

The free chlorine residual was monitored at the point of entry to the distribution system with a target residual of >1.00 mg/L - <1.30. Benmiller's average for 2025 was 1.55 mg/L.



Flows

The Benmiller well supply PTTW (permit to take water) #3180-BJKPVH was issued December 27, 2019 which allows a maximum of 196 cubic meters per day to be pumped from Well #2 and expires December 12, 2029. This limit was not exceeded in 2025. The average daily water flow was 42 m³. A full summary of the 2025 flows can be found in the Annual Report.

The Drinking Water Works Permit (DWWP) #080-204 Issue #4 for the Benmiller Drinking Water System was issued on June 19, 2020. The maximum total daily flow is 196 cubic meters per day and the maximum instantaneous flow is 7.6 liters per second. The well is restricted to 2.27 L/s.

The limiting factor regarding flow is chlorine contact time in the chlorine contact reservoir. In order to meet the regulatory CT requirements, increased flows beyond this must have adequate free chlorine residual to counter the decreased retention time in the chlorine contact reservoir.

The combination of maximum flows through the chlorine contact reservoir and minimum free chlorine residuals exiting the contact reservoir did not exceed the limitations in 2025 as recorded by the flow meters and the online chlorine analyzer.

The maximum daily flow in 2025 was 181 cubic meters or 92.38% of capacity.

The 2025 average daily flow was 42 cubic meters or 21.43% of capacity.

Precautionary Boil Water Notices

There was one Precautionary Boil Water notice placed on the Benmiller water system in 2025 - AWQI #169293 due to a watermain break.

Boil Water Advisory

There was one Boil Water Advisory issued by the Huron Perth Public Health (HPPH) on the Benmiller water system in 2025 - AWQI #169293.

Annual Ontario Ministry of the Environment Inspection

Ron Burrell, Ministry of the Environment, Conservation and Parks (MECP) Drinking Water Inspector, inspected the water system and examined the water quality and operational records in May, 2025. There were no non-compliant issues. The rating was 100%.

Non Conformance

There was (0) instances of nonconformance from the Internal Audit:

Adverse Water Quality Indicators

There were no instances of adverse water to report in 2025.

Exceedances

There were no exceedances to report in 2025



Infrastructure Assessment

Regular contact is maintained with ACW's representative. The JobsPlus program is continually updated with preventative and corrective maintenance issues. A complete summary can be forwarded to the client upon their request. Through regular communication between the operating authority and the client, capital items are discussed. A list of capital items and concerns was forwarded to ACW's representative in 2025.

The annual Management Review was conducted by the operating authority on November 5, 2025 as per the DWQMS requirement in Element 14. Regular discussions between the client and the operating authority for this water system are continued throughout the year by emails, phone calls, and meetings as per the requirements of Element 15 of the DWQMS.

The Internal Audit was last completed on October 7, 2025, there were three minor non conformances noted. The last Risk Assessment was completed in October 2025. An Emergency Response Exercise was not conducted by Veolia in 2025.

An External System (Stage 1) Surveillance Audit was conducted by SAI Global on May 6, 2025, Certificate # 0225715 was issued on September 23, 2025.

Sarah Telford - Compliance Coordinator
Veolia Water Canada, Inc.

100 Cove Road, P.O. Box 185 Goderich, Ontario N7A 3Z2
Tel 519-524-6583 ext 317 - Fax 519-524-9358
sarah.telford@veolia.com
www.veoliawaterna.com