



PRECAUTIONARY BOIL WATER NOTICE LIFTED

DATE: Friday, May 27, 2022

TO: Residents of Huron Sands Water System

**SAFE RESULTS HAVE BEEN RECEIVED FROM SAMPLES COLLECTED IN
THE ABOVE AREA.**

**FOR THAT REASON THE PRECAUTIONARY BOIL
WATER NOTICE HAS BEEN LIFTED.**

Thank you for your cooperation.

VEOLIA WATER CANADA

For more information contact: 519 524-6583

SGS Canada Inc.
 657 Consortium Court
 London - Ontario - N6E 2S8
 Phone: 519-672-4500 FAX: 519-672-0361

27-May-2022

Veolia Water (Huron Sands)
 Attn : John Graham

Date Rec. : 24 May 2022
 LR Report: CA21229-MAY22

P.O. Box 185, 100 Cove Road
 Goderich, ON
 N7A 3Z2, Canada

Copy: #1

Phone: 519-524-6583
 Fax:519-524-9358

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL	Field Turbidity NTU
1: Analysis Start Date		---	---	25-May-22	25-May-22	25-May-22	---
2: Analysis Start Time		---	---	17:10	17:10	16:30	---
3: Analysis Completed Date		---	---	27-May-22	27-May-22	27-May-22	---
4: Analysis Completed Time		---	---	14:40	14:40	14:40	---
5: MAC		---	---	0	0	---	---
6: RW Raw	24-May-22 08:30	9.0	---	0	0	---	0.59
7: TW Treated	24-May-22 08:20	9.0	1.45	0	0	< 10	0.33
8: DW South SS	24-May-22 08:05	9.0	1.31	0	0	< 10	---

MAC - Maximum Acceptable Concentration

Method Descriptions

Units	Description	SGS Method Code
cfu/100mL	E.Coli by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001
cfu/1mL	Heterotrophic Plate Count (HPC) by SP (using SPCA)	ME-CA-[ENV]MIC-LAK-AN-002
cfu/100mL	Total Coliform by MF (using DCM)	ME-CA-[ENV]MIC-LAK-AN-001



Cristal Schuster
 Project Specialist-London,
 Environment, Health & Safety